


Certificate of Compliance

Certificate Number **20081205-R9700B**
Report Reference **2008 December 5**
Issue Date **2008 December 5**

Page 1 of 2



Issued to: 3M Company

3M Center
St Paul, MN 55144

*This is to certify that
representative samples of*

Fill, Void or Cavity Materials
Fire Barrier 1000 NS Sealant

Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety:

ANSI/UL 1479 Fire Tests of Through-Penetration Firestops
ANSI/UL 2079 Tests for Fire Resistance of Building Joint Systems

Additional Information:

See addendum for system listings

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.


Look for the UL Classification Mark on the product

Issued by:


Mona Couloute

Underwriters Laboratories Inc.

Reviewed by:


Steven Hoffman

Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number **20081205-R9700B**

Report Reference **2008 December 5**

Issue Date **2008 December 5**

Page 2 of 2



**Underwriters
Laboratories Inc.®**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

FB-1000 NS Sealant for use in Through-Penetration Firestop System Nos. C-AJ-0060, C-AJ-1292, C-AJ-1364, C-AJ-1556, C-AJ-2214, C-AJ-2216, C-AJ-2226, C-AJ-2227, C-AJ-2228, C-AJ-2241, C-AJ-2242, C-AJ-2255, C-AJ-2278, C-AJ-3150, C-AJ-3300, C-AJ-4070, C-AJ-5125, C-AJ-6002, C-AJ-7096, C-AJ-8075, F-A-0011, F-A-0013, F-A-0015, F-A-0024, F-A-1041, F-A-1042, F-A-1046, F-A-1050, F-A-2033, F-A-2041, F-A-2045, F-A-2097, F-A-2098, F-A-2109, F-A-2110, F-A-2115, F-A-3017, F-A-3052, F-A-5028, F-A-5029, F-A-8007, F-A-8010, F-A-8034, F-B-1017, F-B-2005, F-B-2006, F-B-2042, F-C-2343, F-C-2344, W-J-1156, W-L-1157, W-L-1341, W-L-2172, W-L-2173, W-L-2174, W-L-3129, W-L-3130, W-L-5089, W-L-5124, W-L-7146, W-L-8022.

FB-1000 NS Sealant for use in Joint System Nos. BW-S-0007, FF-S-1027, FW-D-1070, HW-D-0060, HW-D-0061, HW-D-0118, HW-D-0119, HW-D-0120, HW-D-0168, HW-D-1011, HW-D-1012, HW-D-1015, HW-D-1020, HW-S-0028, HW-S-0029, WW-D-1023 and WW-S-1030.

Issued by:

Mona Couloute
Mona Couloute

Underwriters Laboratories Inc.

Reviewed by:

Steven Hoffman
Steven Hoffman

Underwriters Laboratories Inc.